

QUESTIONS & ANSWERS
RFP # 15-002-37
DOWNTOWN DISTRICT COOLOING LOOP

Question:

1. On print M1.1, the bottom left hand corner has two 8" lines going to the 150 Washington Ave. There is a reference to note # 2, where is this note?

Response: Delete reference to note on sheet M1.1 and M1.2 .

Question:

2. Also there is a note for continuation of this 8" pipe, see sheet M1.2. There appears to be about 90 feet gap between M1.1 and M1.2. where the 8" pipe will run.

Response: Contractor shall account for and install piping in existing underground tunnel between 157 Poplar and 150 Washington.

All other questions have been answered by clarification per addenda.